CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-0895:111 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Linear Corporation, 2055 Corte Del Nogal, Carlsbad, CA 92009

Contact: John Kuivinen (760) 438-7000 x 227

DESIGN: Model PERS-2400 emergency reporting system. Unit is a receiver for use with as smoke

detector accessory. Refer to listee's data sheet for additional detailed product description

and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as smoke detector accessory for use with listee's separately listed smoke

detectors. For indoor use only.

NOTE: Unit is <u>NOT</u> a fire alarm control unit.

07-24-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 19, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager